

Attestation

LEED v4.1 BETA

On the 24th of October 2023, Eurofins Product Testing A/S received a sample of a primer with the product name:

Sigma Multiprimer Aqua

supplied by

PPG Coatings Nederland BV

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000, EN 16516, and ISO 11890-2, testing standards (See test report no. 392-2023-10497201_A_EN and no. 392-2023-00497202_XH_EN).

The test results of the tested sample indicate that the product qualifies for LEED v4.1 BETA (July 2020) projects in Europe by showing compliance with the specifications for VOC emissions and VOC content by complying with:

VOC emissions specifications in LEED EQ credit "Low-Emitting Materials" for LEED projects outside the US:

- The requirements of LEED v4.1 BETA (February 2021) by not exceeding the LCI values mentioned in the German AgBB Testing and Evaluation Scheme (2018), showing an overall R-value below or equal to 1 and having a TVOC according to EN 16516 below or equal to 1,000 µg/m³, a sum of VOC without LCI less than 100 µg/m³ and a formaldehyde emission below or equal to 10 µg/m³; all after 28 days.

VOC content specifications in LEED EQ credit "Low-Emitting Materials" for LEED projects in Europe:

- The requirements of LEED v4 and LEED v4.1 BETA (February 2021): EU Decopaint Directive 2004/42/CE for 'One-pack performance coatings' having a VOC content below 140 g/L

9 December 2024



Laura Hartung Sørensen
Analytical Service Manager

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.